



NOTES

1. Concrete Grades:  
Insitu concrete 20MPa  
Extruded concrete 25MPa
2. Bedding:  
To consist of 300mm (min) GAP65 subbase in roads and 100mm GAP40 in footpaths.
3. Jointing:  
Extruded channels cracking control joints formed or saw cut to a minimum depth of 30mm at max 4.00m intervals for unreinforced channels and 6.00m (max) for reinforced channels/nib. If there is a footpath adjacent to the channel/nib the sawcut shall coincide with the concrete footpath joint.

PREPARED BY:



**AUCKLAND CITY**  
Transport

HAURAKI GULF ISLANDS  
CHANNELS

SCALE : NTS.

DRAWN : PH

ISSUE DATE : 11/2008

APPROVED :

PLAN No. ISSUE A

2008/0202