



NOTES

- Under Channel Drains are required.
- For Type 2 Contraction Joints are to be saw cut at 5m max. centres. Saw cuts to be 1/4 depth of concrete by 6mm wide.
- All Privateways are to be drained to a Catchpit and connected to a Drainage System to the satisfaction of the Engineer.

4.

SUBGRADE CBR	SUBBASE REQUIRED		
	TYPE 1	TYPE 2	TYPE 3
≥ 7	150	0	50
5	200	100	100
≤ 3	350	150	200

PREPARED BY OPUS:

AUCKLAND
City Council

AUCKLAND CITY
Transport

HAURAKI GULF ISLANDS
URBAN PRIVATE WAY :
FOUR DWELLINGS OR MORE

SCALE : NTS
DRAWN : LJC
ISSUE DATE : 1/2009
APPROVED :

PLAN No. 2008/0304
ISSUE B