



NOTES

1. Concrete strength shall be 20 MPa at 28 days.
2. Excavation shall be fenced and lit at night.
3. Existing concrete to be cut out neatly and removed.
4. Brick or precast concrete paving units may be used only between the property boundary and the rear of the footpath to comply with NZS 3116.1981 Interlocking Concrete Paving.
5. Business crossing dimensions to be specifically designed to accommodate all vehicle types that may be required to access the site.
6. Residential crossing to be minimum 150mm thick concrete.
7. Business crossing shall be minimum of 200mm thick concrete without mesh. 8. Refer also to Sheet 2008/0619 - TYPICAL VEHICLE CROSSING SLOPE DETAILS.

PREPARED BY OPUS:



**AUCKLAND CITY**  
Transport

HAURAKI GULF ISLANDS  
VEHICLE CROSSING FOR USE  
WHERE ROAD DRAINAGE IS  
VIA GRASS BERM

SCALE : NTS

DRAWN : LJC

ISSUE DATE : 11/2008

APPROVED :

PLAN No. ISSUE B

2008/0620