

**NOTES**

1. Groundwater drain through anchor block 2x DN 80 PVC drain pipes. Cover upstream opening with filter membrane and anchor the filter membrane to a minimum of 150mm deep in the bedding material on the upstream side.
2. Reinforcing for concrete anchor block to be shown on design drawing.
3. For PVC and PE pipes, concrete anchor blocks are to be located at pipe joints and not exceed 6m spacings.



DETAIL:

**ANCHOR BLOCK DETAIL****MANUKAU CITY COUNCIL**Engineering  
Quality  
Standards

DETAIL No:

**D13**

UPDATED:

**OCT 2004**